# Alvarez Fire Protection (sample)

License AZ-FE-00000 · (520) 555-0142

## CUSTOMER AND SITE

**Santa Cruz Taqueria (sample)**
Maria Santos · (520) 555-0199
Inspection: annual

**Santa Cruz Taqueria**
1420 Main St, Tucson, AZ, 85701
Completed 2026-11-07 · Next due 2027-11-07

## EQUIPMENT

| Tag | Location | Type | Size | Result | Deficiencies |
|---|---|---|---|---|---|
| ALV-7K3M2P | Kitchen, by the walk-in | ABC dry chemical | 10 lb | Pass | None |
| ALV-9Q4T8R | Dining room, east exit | ABC dry chemical | 5 lb | Pass | None |
| ALV-2W6Y5N | Prep line | Class K | 6 L | Fail | Pressure gauge low; Tag missing |

Notes: Sample report. Fictional data.

## SIGNATURES

**TECHNICIAN**
**J. Alvarez**

**CUSTOMER**
**Maria Santos**

Verify at inspectrenew.com/verify/SAMPLE0001
Scan the code to see the inspection date, the next due date, and the SHA-256 of this PDF.
Not affiliated with NFPA.